

Tambaram City Municipal Corporation

SANITARY CERTIFICATE

Roc.No.001327/2024/H1


Dated:12.04.2024

Certified that **SHREE GUGAN'S SCHOOL, NO.54/5, SCHOOL STREET, SELAIYUR, EAST TAMBARAM, CHENNAI-600073** has been inspected by the Sanitary Inspector and the Building and premises are found satisfactory on the following aspects.

1. The ventilation & Lighting Facilities are Satisfactory.
2. The building is maintained properly.
3. The room and surroundings are maintained neat and clean.
4. The sanitary arrangements provided are adequate and satisfactory.
5. The supply of drinking water is wholesome.

The Sanitary certificate may be issued subject to the following conditions:

- ❖ The garbage generated within the building premises should be collected and disposed of properly by appointing required sanitary staff.
- ❖ On no account the garbage should be burnt.
- ❖ This certificate issued is liable to be cancelled at any time on infringement of any of the above set conditions and for improper maintenance of sanitation, improper maintenance of the building as well as urinals and toilets in the buildings.
- ❖ Adequate fire safety precautions should be made.
- ❖ Safe and protected drinking water alone should be supplied to the children for consumption.
- ❖ The premises should be inspected periodically for mosquito breeding places and all control measures should be taken to keep the premises mosquito free.
- ❖ For running a food establishment / canteen, permission should be obtained from the food safety department.
- ❖ incinerator shall be installed for safe disposal of sanitary napkins.
- ❖ The lab in charge should be well trained in handling the fire extinguisher.
- ❖ No smoking board should be displayed at predominant places with in the premises.
- ❖ No account sale of tobacco products should be permitted within the premises.
- ❖ Any occurrence of communicable disease should be notified to the Public Health Department.
- ❖ One time use and throw plastic is banned strictly by the Tamil Nadu Government. So ensure "Plastic Free" in your premises.
- ❖ Issued on 12.04.2024 Valid upto 2024-2025 Academic year.



[Signature]
Sanitary officer
Tambaram City Municipal Corporation

TEST REPORT

ULR No:TC100512400001575F

Page 1 of 2

LRI No: AEL24040454A

Report Date: 23.04.2024

CUSTOMER DETAILS

Customer Name & Address: **M/s Shree Gugans School**
 54/5, School Street, Selaiyur,
 Tambaram, Chennai – 600 073.

Customer Reference: Test Request dated: 18.04.2024



SAMPLE DETAILS

Product Category	Water	Sample Code	FD24040184
Sample Name	Drinking Water	Sample Received on	18.04.2024
Sample Description by Customer	RO Water	Sample Conditions at Receipt	Fit for Analysis
Sample Quantity & Packing	1 Ltr X 3 No's	Test Commenced on	18.04.2024
Sampled by	Laboratory Authorized Sampler	Test Completed on	22.04.2024
Testing performed at	Permanent Facility	Information Provided by Customer	Aqua RO

DETAILS OF SAMPLING

Sample Source	Aqua RO	Date of Sampling	18.04.2024
Sampling Procedure	AEL/QAD/SOP/006	Sample Temperature	28°C

TEST RESULTS - CHEMICAL DISCIPLINE

Sl. No.	PARAMETERS	TEST METHOD	UNIT	RESULT	Requirements as per IS 10500:2012	
					Acceptable Limit	Permissible limit in the absence of Alternate Source
1	pH value@25°C	IS 3025 (Part-11):2022	--	6.61	6.5 to 8.5	No Relaxation
2	Electrical Conductivity@25°C	IS 3025 (Part-14):2013	µS/cm	309	--	--
3	Colour	IS 3025 (Part-4):2021	Hazen	< 1	Max 5	Max 15
4	Odour	IS 3025 (Part-5):2018	--	Agreeable	Agreeable	Agreeable
5	Turbidity	IS 3025 (Part-10):2023	NTU	< 1	Max 1	Max 5
6	Total Dissolved Solids@180°C	IS 3025 (Part-16):2023	mg/L	156	Max 500	Max 2000
7	Total Hardness as CaCO ₃	IS 3025 (Part-21):2009	mg/L	30.24	Max 200	Max 600
8	Calcium as Ca	IS 3025 (Part-21):2009	mg/L	6.46	Max 75	Max 200
9	Magnesium as Mg	IS 3025 (Part-40):1991	mg/L	3.40	Max 30	Max 100
10	Chloride as Cl	IS 3025 (Part-46):1994	mg/L	70.4	Max 250	Max 1000
11	Total Alkalinity as CaCO ₃	IS 3025 (Part-32):1988	mg/L	40.2	Max 200	Max 600
12	Phenolphthalein Alkalinity	IS 3025 (Part-23):2023	mg/L	NIL	--	--
13	Carbonate Hardness as CaCO ₃	IS 3025 (Part-23):2023	mg/L	30.24	--	--
14	Non-Carbonate Hardness as CaCO ₃	IS 3025 (Part-21):2009	mg/L	NIL	--	--
15	Iron as Fe	IS 3025 (Part-21):2009	mg/L	< 0.05	Max 1.0	No Relaxation
16	Sulphate as SO ₄	IS 3025 (Part-53) (1,10 Phenanthroline Method):2003	mg/L	16.5	Max 200	Max 400
17	Nitrate as NO ₃	IS 3025 (Part-24) Sec 1:2022	mg/L	< 2	Max 45	No Relaxation
18	Silica as SiO ₂	IS 3025 (Part-34):1988	mg/L	3.94	--	--
		IS 3025 (Part-35):1988	mg/L			

Asha.A
Asha.A

TM - Biological
 Authorized Signatory

Dhasarathan.B
Dhasarathan.B

TM Chemical
 Authorized Signatory

The results are related to the sample tested and this report shall not be reproduced except in full without the written approval of the laboratory.



ASIAN ENVIRO LABS PVT LTD

#.1, 200 Feet Pallavaram to Thuraipakkam Radial Road,
Zamin Pallavaram, Chennai - 600 043. Tamil Nadu.

COPY



TC - 10051

TEST REPORT

ULR No:TC1005124000001575F

Page 2 of 2

LRI No: AEL24040454A

Report Date: 23.04.2024

TEST RESULTS - BIOLOGICAL DISCIPLINE

Sl. No.	PARAMETERS	TEST METHOD	UNIT	RESULT	Requirements as per IS 10500:2012
1	Total Coliform	IS 15185:2016	CFU/100ml	< 1	Shall not be detectable in any 100ml sample
2	Escherichia Coli	IS 15185:2016	CFU/100ml	< 1	

Note: < 1 CFU/100ml is considered as not detected.

Remarks: The above water sample complies with Acceptable Limits of Drinking Water Specification as per IS 10500:2012 with respect to above parameters tested.

End of Report

Asha.A

TM - Biological
Authorized Signatory



Dhasarathan.B
TM Chemical

Authorized Signatory

The results are related to the sample tested and this report shall not be reproduced except in full without the written approval of the laboratory.

AEL/QAD/FRM/100/01-00

www.asianenvirolabs.com

E-mail : info@asianenvirolabs.com

Tel.: 91-44-2266 0411, 2266 0511